

## TEST REPORT

Report No.: HTL/W/02/24-25

Reporting Date: 02/04/2024


1.	Name & Address of Customer	<b>M/S IDEAL PUBLIC SCHOOL</b> <i>Plot no.-5, Jagma Enclave, Village-Agwanpur, Faridabad.</i>
2.	Sample Id	<b>HTL/W/2430031002</b>
3.	Sample Description	<b>Drinking water</b>
4.	Sample Quantity	<b>2.0 Ltr.+500 ml</b>
5.	Date of Sample Received	<b>30/03/2024</b>
6.	Period of analysis	<b>30/03/2024 - 02/04/2024</b>
7.	Sample collected by	<b>HTL Representative</b>

SR. NO	TEST PARAMETERS	UNIT	TEST METHOD	RESULTS	LIMIT AS PER IS-10500-2012	
					ACCEPTABLE LIMITS	PERMISSIBLE LIMITS
<b>TABLE 1-ORGANOLEPTIC AND PHYSICAL PARAMETERS</b>						
1.	pH (at 25°C)	---	IS 3025: (P-11)	7.12	6.5-8.5	No Relaxation
2.	Odour	---	IS 3025: (P-5)	Agreeable	Agreeable	Agreeable
3.	Colour	Hazen	IS 3025: (P-4)	< 1.0	5.0	15.0
4.	Taste	---	IS 3025: (P-7)	Agreeable	Agreeable	Agreeable
5.	Turbidity	NTU	IS 3025: (P-10)	< 1.0	1.0	5.0
6.	Total Dissolved Solids	mg/l	IS 3025: (P-16)	78	500	2000
<b>TABLE 2-GENERAL PARAMETERS</b>						
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	IS 3025: (P-21)	27	200	600
8.	Calcium (as Ca)	mg/l	IS 3025: (P-40)	9.40	75	200
9.	Chlorides (as Cl)	mg/l	IS 3025: (P-32)	18	250	1000
10.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	IS 3025: (P-23)	21	200	600
11.	Free Residual Chlorine	mg/l	IS 3025: (P-26)	< 0.1	0.2	1.0
12.	Magnesium (as Mg)	mg/l	IS 3025: (P-46)	1.48	30	100

Remarks :- The sample is confirm IS 10500- 2012 Fit for drinking.

**-END OF TEST REPORT-**


  
**CHECKED BY**


  
**AUTHORIZED SIGNATORY**


**Note:-**

1. Test results listed refer only to the sample and applicable parameters, Endorsement of products is neither inferred nor implied.
2. The sample will be stored up to one month (in case of non perishable items only) from the date of issue of test report.
3. This is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
4. Total liability of the laboratory is limited to the invoiced amount.



 18/1 Mathura Road, Ajronda, Near-S: Hospital Faridabad, Haryana-121001

 +91 01292982027, +91 989141 4181  
+91 92687 23027

 info@hindustantestinglab.com,

REGISTRATION OF SOCIETIES  
New Delhi

# Health Department, Haryana (Faridabad)

O/o Civil Surgeon, Faridabad

## Hygiene Certificate

No. HHC/Fbd/2024/25/36

Date 25/04/2024

Certified that the inspection of the Ideal Public School.....

Plot - No - 5, Jagmal Enclave, Agwanpur, Faridabad.....

.....School has been carried out on Date..8/4/2024.....The

Hygienic condition was found

satisfactory/Unsatisfactory

The above Certificate is valid till 31/3/2025.... Date

Jayyamt

Signature with Seal:  
Dy. Civil Surgeon (School Health)  
Faridabad